


LEGEND

SITE BOUNDARY	
LAND OWNERSHIP BOUNDARY	
PROPOSED BUILDING	
EXISTING BUILDING	
MASTERPLAN AREA SUBJECT TO FUTURE DEVELOPMENT	
EXISTING WATERMAIN	
PROPOSED WATERMAIN (POTABLE WATER)	
PROPOSED WATERMAIN (225 OD PE100 SDR11 PIPE) MATERIALS MUST BE IN ACCORDANCE WITH UISE EIREANN STANDARDS	
PROPOSED WATERMAIN (90 OD PE80 SDR11 PIPE) MATERIALS MUST BE IN ACCORDANCE WITH UISE EIREANN WATER STANDARDS	
PROPOSED FIRE HYDRANT	FH
PROPOSED SLUICE VALVE	SV
PROPOSED SCOUR VALVE	ScV
PROPOSED AIR VALVE	AV
PROPOSED BLANK FLANGE	BF
ELECTROMAGNETIC WATERMETER & CHAMBER TO UISE EIREANN DETAIL STD-W-26. KIOSK REQUIRED TO BE DETAIL STD-W-36. KIOSK LOCATION TO BE AGREED WITH ARCHITECT	




MAP SHEETS

1:1,000	4743-05
1:1,000	4682-25
1:2,500	4693 - C
1:2,500	4744 - A

Tailte Éireann Licence No. CYAL50511569
© Tailte Éireann - Surveying.

© PUNCH Consulting Engineers
This drawing and any design hereon is the copyright of the Consultants and must not be reproduced without their written consent. All drawings remain the property of the Consultants. Figured dimension only to be taken from this drawing. Consultants to be informed immediately of any discrepancies before work proceeds.



Rev	Amendment	By	Date	Rev	Amendment	By	Date	Client
CO1	ISSUED FOR PLANNING	SK	2024-05-15					



Project: PARKWAY VALLEY LRD		Title: PROPOSED WATERMAIN LAYOUT	
Drawn: PJ Mulcahy	Date of issue: 2025-09-18	Technical Check: PJ Mulcahy	Engineer Check: Tracey O'Connell
Project No: 231171	Model Ref: 231171-PUNCH-XX-XX-M2-C-0301	Drawn Status: AO (Planning)	Approved: Julie Tiernan
Scale @ A1: 1:500	Document No: 231171-PUNCH-XX-XX-DR-C-0301	Revision No: CO1	